

# Annexure C


Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. P-28816

Dated: 23/6/23

It is certified that an inspection team headed by MIDC  
(Name of Officers with designation) from Joshi S.V. Filter Inspector  
(Name of Department/ Office) inspected the Regional Public Health Lab Nagpur  
(Name & Address of the school) on 4/5/2023 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the Institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of .....

\* Signature with Seal: 

Name : A.M. Kawale

Designation : Deputy Engineer MIDC GMSU 4077  
Sub-Div

Assistant Engineer of Sub-Division  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : .....


To

The Principal  
K.D.K. International School Buthori

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

58 | Page

  
Principal  
KDK International School  
Buthori, Nagpur

  
Manager  
KDK International School  
Buthori, Nagpur

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

"अ"

राज्य/प्रदेशिक/जिल्हा आरोग्य प्रयोगशाळा Nagpur बुरजनी क्र. 02122546014

पाण्याच्या नमुन्याचा सूक्ष्मजीवीय अहवाल

पाठविण-वाचे, नाव व पत्ता : Dy. Eng. MLDC (E&M) Sub Dn Bulibori  
 पाठविण-वाचे पत्र क्रमांक व दिनांक : B51514/2023, 4/5/2023  
 प्रयोगशाळा संदर्भ क्रमांक : 12678-81  
 नमुना घेतल्याचा दिनांक : 4/5/2023  
 नमुना शोधलेल्याचा दिनांक : 4/5/2023  
 परीक्षण सुरु केल्याचा दिनांक : 4/5/2023

अ.क्र.	नमुन्याचे प्रकार	परीक्षाचे विभाग		इतर अभिप्राय
		प्रति 100 मि.ली. नमुन्यातील संभाव्य धूराणूंची संख्या		
		कोलीफॉर्म	थर्मोटोलीरेंट जीवाणू	
1)	Tap K.D.K International School Bulibori	0	—	Fit for drinking purposes
2)	Endorama Synthetics Ltd.	0	—	
3)	Morarji Textiles Ltd.	0	—	
4)	Cent Pyres Bulibori	0	—	

*[Handwritten signature]*

*[Handwritten text]*

अभिप्राय :  
 पिण्यात अयोग्य पाण्यावर योग्य प्रभापाता रस्तोरीनची प्रक्रिया बरेचदांतर्त व सूक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यात योग्य असल्याची खात्री झाल्यानंतरले पाणी पिण्यासाठी वापरता येईल.  
 अहवाल क्रमांक : 12678-01/2023  
 अभिप्राय तारिखे कळविल्याचा दिनांक : 09/5/23  
 प्रत सादर  
 १) मिलात आरोग्य अधिकारी, मिलात पोस्ट, जिल्हा Bulibori  
 २) Principal K.D.K. International School  
Bulibori Nagpur  
 ३) Manager KDK International School  
Bulibori



TRUE TRANSLATION.

GOVT. OF MAHARASHTRA  
PUBLIC HEALTH SERVICES  
REGIONAL HEALTH LABORATORY, NAGPUR.

Telephone/Fax No. 0712-2546014.

MICRO ORGANISM REPORT ON WATER.

Name of Sender: Dy. Eng. MIDC(E&M) Sub. Dn. Butibori

Letter No. and date of Sender: B51514/2023, 4.5.2023


Reference no. of Laboratory - 12678-81.

Date of taking sample: 4.5.2023.

Date of Reaching sample - do-

Date of starting inspection -do-

Sr. No.	Nature of sample	Conclusion of inspection No. of micro organism germs per 100 M.L. Coliforms Thermot Olerant Germs	Other remarks.
1) Tap	K.D.K. International School Butibori	0 -	Suitable for drinking
2) Tap	Indorama Synthetics Ltd.	0	



*Principal*  
Principal  
K.D.K. International School  
Butibori Nagpur

*Manager*  
Manager  
KDK International School  
Butibori

3) Tap	Moraji Textiles Ltd.	o	
4) Tap	Ceat Tyres Butibori	o	

**Remarks**

On making process of chlorine in the unsuitable for drinking water and on micro-mechanism re-inspection it is ensured that the water can be used for drinking.

Report No. 12678-81 2275, dated 26.2./09.5.2023.


Copy submitted to:

1. District Health Officer, Zilla Parishad, Nagpur.
2. The Surgeon, District Hospital, District Nagpur.


Sd/-  
In-charge Officer,  
Regional Health Laboratory,  
Opp. MIDC.



// TRUE TRANSLATION //



**ATTESTED**  
*[Signature]*  
26/6/2  
Mrs. CHANCHAL KHURAN  
Advocate & Notary  
Resi. Off. H/No. 410/3,  
Mecosaabagh, NAGPUR-4400



*[Signature]*  
K.D.K. International School,  
Butibori Nagpur

**Maharashtra Industrial Development Corporation**

( A Government of Maharashtra Undertaking)

**Office of the Deputy Engineer, MIDC Sub-Division E & M  
MIDC Industrial Area Butibori.**

E-mail : "debutiboriem@midcindia.org" ☎ . 07104-265252



E-office/No./DE-I/ I-P-28316 /of 2023,

Date:-23/06/2023

To,  
The Principal,  
KDK Int. School,  
Butibori

**Sub:- Nagpur (Butibori) Indl. Area...**

Issue of test report regarding probability of water sample for  
the month of May-2023.

**Sub:-** Your letter No. Nil dated 20.06.2023.

Sir,

Please find herewith Butibori Indl. Area and tested from Regional  
Public Health Laboratory Nagpur.

The report for the month of May-2023 is enclosed herewith.

Thanking you.

Yours faithfully

Deputy Engineer,  
MIDC, Sub-Division (E&M)  
Butibori.

Principal  
K.D.K. International School  
Butibori Nagpur

Principal  
KDK International School  
Butibori